

EC-CERTIFICATE OF CONFORMITY

Certificate No: 0809 - CPD - 0634

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the

Emergency exit locks, types EL 402 and EL502 operated by push pad PPE004

**used on doors on escape routes,
with the property profile:**

3	7	6	0	1	3	4	2	B	B/D
---	---	---	---	---	---	---	---	---	-----

**presented also on page 2
placed on the market by**

Abloy Oy

**Wahlforssinkatu 20
FIN-80101 Joensuu**

and produced in the factory

Abloy Oy, FIN-80101 Joensuu

are submitted to the manufacturer's factory production control, including continuous testing. The initial type-testing of the products, the inspection of the factories and the factory production controls, which are under continuous surveillance, have been performed. This certificate attests that the provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 179:2008

were applied and that the the manufacturer's factory production controls and products and their properties mentioned on page 2 fulfil the requirements in Annex ZA of the standard EN 179:2008

This certificate was first issued on 2009-06-16 and remains valid as long as the conditions presented in the harmonised standard are fulfilled and the harmonised standard is not modified significantly or the manufacturing conditions in the factories or the FPC itself or existing contracts are not modified significantly.

Espoo 16.06.2009



Liisa Rautiainen
Assessment Manager



Jarmo Ruohomäki
Senior Research Scientist

Product	Property	Grade, category or type
Locks EL 402 and EL 502 With push plates	Category of use	Grade 3
	Durability	Grade 7 (200 000 test cycles)
	Door mass	Grade 6 (200 kg)
	Suitability for use on fire/smoke doors	Grade 0
	Safety	Grade 1
	Corrosion resistance	Grade 3 (high resistance)
	Security	Grade 4 (3000 N)
	Projection of operating element	Category 2 (low projection)
	Type of operation	Type B (push pad operation)
	Field of door application	B/D (outwardly/inwardly opening single exit door only)

Manufacturing site: Joensuu